



We help ideas meet the real world



Compliance Statement

No. 2011-173

Data communication cable, Category 6

Company

Excel
Excel House
Junction Six Industrial Park
Electric Avenue
Birmingham B6 7JJ
United Kingdom

Product description

Unscreened cable (U/UTP) characterised up to 250 MHz
Horizontal floor wiring cable, 100 Ω
4 twisted pairs
Flame retardant, halogen free

Product identification

100-071

Generic cabling and cabling components standards - Category 6 cable requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- IEC 61156-5:2009 (Ed. 2.0)
- EN 50173-1:2011
- EN 50173-2:2007 including amendment A1:2010
- EN 50288-6-1:2003
- ANSI/TIA-568-C.2:2009
-

Standards for flame retardancy

- IEC 60332-1-1:2004
- IEC 60332-1-2:2004

Technical report

DELTA-N313010-01, DANAK-19J2516

EC Cabling product ID

5168

Certificate valid until

20 July 2012

This product has been tested by EC Cabling Group of DELTA and complies with the requirements of the above specified standards and "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The product takes part in a maintenance of certification schedule, which implies that EC Cabling performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 14 July 2011

Erik Bech
Test Manager

Claude Videt
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.madebydelta.com/cable



DANAK
TEST Reg. no. 19