



We help ideas meet the real world



# Compliance Statement

No. 2010-304

## Data communication cable, Category 6A

### Company

Excel  
Excel House  
Junction Six Industrial Park  
Electric Avenue  
Birmingham B6 7JJ  
United Kingdom

### Product description

Screened cable (S/FTP) characterised up to 500 MHz  
Horizontal floor wiring cable, 100  $\Omega$   
4 foil shielded twisted pairs with overall braid shield  
Flame retardant, halogen free

### Product identification

100-155

### Generic cabling standards, cabling components standard

- ISO/IEC 11801 2<sup>nd</sup> edition:2002 and IEC 61156-5: Edition 2.0 2009-02
- ISO/IEC 11801 amendment 2:2010
- EN 50173:2007
- ANSI/TIA-568-C.2

### Standard for flame retardancy

- IEC 60332-1-[1,2] (2004-07)

### Technical report

DELTA-N312834-01, DANAK-19J2346

### Manufacturer code

1745B

### Certificate valid until

1 December 2011

This product has been tested by EC Cabling Group of DELTA and complies with the requirements of the above specified standards and "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The product takes part in a maintenance of certification schedule, which implies that EC Cabling performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 1 December 2010

Erik Bech  
Test Manager

Claude Videt  
Project Manager

DELTA

Venlighedsvej 4  
2970 Hørsholm  
Denmark

Tel. +45 72 19 40 00  
Fax +45 72 19 40 01  
www.delta.dk/cable



TEST Reg. no. 19